



PLANS REVIEW – FIRE SYSTEMS

Chambers County Fire Marshal's Office

102 Airport Rd./PO Box 957, Anahuac, TX 77514

Phone: 409-267-2494 FAX: 409-267-8497 Email: firemarshal@chamberstx.gov

Applicant Information

Owner Information

Name:	Name:
Address:	Address:
City: State: Zip:	City: State: Zip:
Phone:	Phone:
Email:	Email:

Facility Information

Contractor/Installer

Facility Name:	Name:
Address:	Phone:
City: State: Zip:	Email:

Applicable Standards

- Fire Code: IFC 2015 & Chambers County Fire Code Amendments
- Building Code: IBC 2015
- NFPA 13, 2013
- NFPA 70, 2014
- NFPA 72, 2013

Construction/Design IBC 2015

Occ. Classification(s) (Ch. 3):	Occ. Load(s) (1004):
---------------------------------	----------------------

Plan Information

Fees

<input type="checkbox"/> Fire Alarm or	# of Devices (horns, strobes, heads, etc.):
<input type="checkbox"/> Fire Sprinkler or	# of Fire Alarm Control Panels:
<input type="checkbox"/> Vent Hood Suppression System or	# of Risers:
<input type="checkbox"/> Paint Booth Suppression System or	
<input type="checkbox"/> Other Fire Suppression System:	
	Total Fee:
	Paid On (date):

Note:

1. Fire alarm systems must be monitored.
2. FDC and PIV must be located remote and out of the collapse zone. Further information may be obtained from Fire Marshal.
3. Signs required to identify FDC, Control Valve doors, and Fire Alarm System rooms.
4. Control Valve/PIV sign required if it is not located in close proximity to the FDC.
5. Fee must be paid before permit is issued.

Applicant Signature:

Name: _____ Date: _____