



Chambers County Fire Marshal's Office **Fire Department Connection (FDC) &** **Control Valve Installation**

APPLICABLE STANDARDS


Applicable standards for all Automatic Sprinkler and Fire Alarm System installations shall include:

- International Fire Code 2015 edition;
- NFPA 13, 2013 edition;
- NFPA 70, 2014 edition;
- NFPA 72, 2013 edition.

REQUIREMENTS FOR UNINCORPORATED CHAMBERS COUNTY

1. The Fire Department Connection (FDC) shall be remote of the building, out of the collapse zone. The collapse zone is a distance away from the building equal to the height of the exterior wall on the side of the FDC.
2. The system must have an indicating type main control valve, preferably accessible from the exterior of the building (such as a Wall-Post Indicator). If the valve is located inside the building, it must be directly accessible via an exterior door (The door must be labeled CONTROL VALVE – AUTOMATIC SPRINKLERS). If an upright Post Indicator Valve (PIV) is used for the control valve, it must be located out of the collapse zone of the building.
3. The potable water supply to automatic sprinkler and standpipe systems shall be protected against backflow as required by the *International Plumbing Code (IFC 912.6)*.
4. Fire Department Connections shall be "Siamese" 2 ½" (inch) NH connections with Knox locking caps. The connections must be located at least 24" (inches) from the ground and no more than 36" (inches) from the ground. The locking caps may be ordered from www.knoxbox.com.
***Note:** If the location is within the City of Baytown LPA or Baytown Fire Department response area, the connection must be a single 5" Storz with locking cap. These areas include the Chambers Town Center, areas along SH146, and CCIDs 1, 2, and 3.
5. All fire department connections must be located no more than 100 feet from a fire apparatus access road, and no more than 100 feet from an accessible fire hydrant.
6. The hydrant serving the FDC must not require the blocking of main driveways or access into the facility.
7. All FDCs must be identified by a sign (912.5).
8. All FDCs and PIVs subject to vehicle impact shall be equipped with impact protection per IFC 2015 (912.4.3/312). Posts shall be no closer than 36" to the FDC or PIV and shall not interfere with their operation.

Remote FDC Detail:




REQUIREMENTS FOR CITY OF BAYTOWN LPA OR RESPONSE AREA*

New buildings within the City of Baytown LPA or Baytown Fire Department response areas need to have an FDC compatible with the Baytown Fire Department. These areas include the Chambers Town Center, areas along SH146, Ameriport, and CCIDs 1, 2, and 3. The requirements for an FDC in these areas shall be all of the above requirements, with the following changes:

1. Fire Department Connections shall be a single 5” (inch) Storz connection with a Knox locking cap (Sec. 912.4.1).
2. The remote 5” Storz connection must be at a 30-degree downward angle to the ground and at least 24” (inches) from the ground and no more than 36” (inches) from the ground.
3. The 30-degree downward angle Storz connections and Knox locking caps may be ordered directly from www.knoxbox.com.

Remote FDC Detail (Baytown response area):



FDC SIGNS

1. All FDCs must be identified by a sign.
2. Signs shall be red with white letters, and be labeled with the letters FDC at least 6” high, and words in letters at least 2” high indicating the address of the facility.
3. All FDCs must also have a sign or placard with at least 1” high letters indicating the type of FDC. Such signs shall read: AUTOMATIC SPRINKLERS or STANDPIPES or TEST CONNECTION, or a combination of these words as applicable.
4. The sign must include the address of the facility it serves.
5. If the location of the FDC is not immediately obvious or visible from the street, a sign indicating the location of the FDC is also required. For example: FDC IN REAR, or FDC with an arrow indicating the location.

EXAMPLES:



and

IF NECESSARY:



or



SPRINKLER CONTROL VALVE SIGNS

1. If the control valve is located inside a building, it must be directly accessible via an exterior door.
2. The door must be labeled CONTROL VALVE – AUTOMATIC SPRINKLERS.

EXAMPLE:



3. If the control valve is located remotely and is not readily identifiable as pertaining to the building it serves, the address must be indicated on the sign as well.

EXAMPLE:

