



# PLANS REVIEW – FIRE ALARM/SPRINKLER

Chambers County Fire Marshal's Office

2128 SH61/PO Box 957, Anahuac, TX 77514

Phone: 409-267-2445 FAX: 409-267-8497 Email: [rdholzaepfel@chamberstx.gov](mailto:rdholzaepfel@chamberstx.gov)

## Project Information

## Applicant Information

Facility Name:	Name:
Address:	Address:
City: State: Zip:	City: State: Zip:
Phone:	Phone:
Email:	Email:

## Designer/Engineer

## Contractor/Installer

Name:	Name:
Phone:	Phone:
Email:	Email:

## Applicable Standards

- Fire Code: IFC 2015 & Chambers County Fire Code Amendments
- Building Code: IBC 2015
- NFPA 13, 2013
- NFPA 70, 2014
- NFPA 72, 2013

## Construction/Design IBC 2015

Occ. Classification(s) (Ch. 3):	Occ. Load(s) (1004):
---------------------------------	----------------------

## Plan Information

## Fees

<input type="checkbox"/> Fire Alarm or <input type="checkbox"/> Sprinkler or <input type="checkbox"/> Vent Hood	# of Devices (horns, strobes, heads, etc.) _____
Fire Alarm System indicated page:	
Sprinkler System indicated page:	
FDC Location:	
FDC Type (5" Storz or 2 1/2" NST?):	
Control Valve Location:	Total Fee:
Control Valve Type (Wall, OS&Y, or PIV):	Paid On (date):

## Note:

1. Fire alarm systems must be monitored.
2. FDC and PIV must be located remote and out of the collapse zone. Further information may be obtained from Fire Marshal.
3. Signs required to identify FDC, Control Valve doors, and Fire Alarm System rooms.
4. Control Valve/PIV sign required if it is not located in close proximity to the FDC.
5. Fee must be paid before permit is issued.

## Approval Signature:

Fire Marshal: \_\_\_\_\_ Date: \_\_\_\_\_