



# FIRE ALARM/SPRINKLER PLANS REVIEW

Chambers County Fire Marshal's Office

2128 SH61/PO Box 957, Anahuac, TX 77514

Phone: 409-267-2445 FAX: 409-267-4133 Email: [rdholzaepfel@chamberstx.gov](mailto:rdholzaepfel@chamberstx.gov)

## Project Information

Facility Name:	Applicant:
Address:	Address:
City:                      State:                      Zip:	City:                      State:                      Zip:
Phone:	Phone:
Email:	Email:

## Designer/Engineer

## Contractor/Installer:

Name:	Name:
Phone:	Phone:
Email:	Email:

## Applicable Standards

- Fire Code: IFC 2009 & Chambers County Fire Code Amendments
- Building Code: IBC 2009
- NFPA 13
- NFPA 70
- NFPA 72

## Construction/Design IBC 2009

Occ. Classification(s) (Ch. 3):	Occ. Load(s) (1002.1):
---------------------------------	------------------------

## Plan Information

## Fees

___ Fire Alarm or ___ Sprinkler or ___ Vent Hood	# of Devices (horns, strobes, heads, etc.) _____
Fire Alarm System indicated page:	
Sprinkler System indicated page:	
FDC Location:	
FDC Type (5" Storz or 2 1/2" NST?):	
Control Valve Location:	Total Fee:
Control Valve Type (Wall, OS&Y, or PIV):	Paid On (date):

## Note:

1. Code required fire alarm systems must be monitored per IFC 2009.
2. FDC and PIV must be located remote and out of the collapse zone. Further information may be obtained from Fire Marshal.
3. Signs required to identify FDC, Control Valve doors, and Fire Alarm System rooms.
4. PIV sign required if it is not located in close proximity to the FDC.
5. Fee must be paid before review is complete.

## Approval Signature:

Fire Marshal: \_\_\_\_\_ Date: \_\_\_\_\_