



- IF MULTIPLE TANKS ARE REQUIRED, THEY MUST BE MANIFOLDED TOGETHER INTO A SINGLE RISER.
- Tank systems must be maintained by the owner, and kept free of obstructions which may prevent access and use by the fire department.

EXAMPLE OF A SINGLE TANK SYSTEM

THIS DETAIL IS A GENERAL REPRESENTATION AND IS NOT TO SCALE

		<p style="margin: 0;">DRY HYDRANT DETAIL</p>	
	<p>REVISION #</p>		<p>FR 001</p>